



NOTES

1. WHERE DIFFERENTIAL MOVEMENT IS A CONCERN, SEE DETAIL SPF- 19.
2. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES [300mm] OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING.

DECK SUPPORTED PENETRATION

2001

NOT DRAWN TO SCALE

SPF-18 B